EZRICE+ INSTRUCTIONS



Read Instruction Manual Completely Before Using EZ Ride



After multiple uses of EZRide+, use multi-tool to tighten all bolts, nuts, and screws on the unit and tow bar.



More info at: www.buyezrideplus.com

Copyright 2022 Shield Innovations LLC



TABLE OF CONTENTS

WarningsPage 2
Tow Bar PartsPage 3
Tow Bar Installation - Chair ClipPage 4
Tow Bar Installation - Slide TubePage 5
Tow Bar Un-InstallPage 6
Tow Bar Hitch Height AdjustmentPage 7
Kickstand InstallationPage 8
Hitch Handle & Kickstand InstallationPage 9
EZ Ride-Wheelchair ConnectionPage 10
EZ Ride-Wheelchair ReleasePage 11
Speedometer & Handle ControlsPage 12
Handle Fold InstructionsPage 13
Handle Bar Reversal InstructionsPage 14
Page 15
Adjustable Neck InstallationPage 16
Page 17
Tow Bar Extension InstallationPage 18
Page 19
How To ChargePage 20
Battery Charger Travel BagPage 21
EZ Ride Safety TagPage 22



The EZRide battery will stop working if not used for a number of months. Turn on unit regularly, check battery display, and charge to full if display shows 2 bars, or less.

Carefully read this manual regarding EZ Ride. EZ Ride is not a toy. Use caution when attached to your wheel chair.

THE MANUFACTURER DISCALIMS ALL LIABILITY RELATING TO DAMAGE CAUSED BY:

- The failure to abide by the instructions in this manual and its instructions.
- EZ Ride being used in ways which is not the intended use.
- EZ Ride being used in ways contrary to applicable laws on safety.
- Tampering with parts that operate the EZ Ride in an efficient manner.
- Incorrect assembly.
- Changes made to EZ Ride function and design without permission of the manufacturer.
- Use of non-original parts or parts that are not suitable for the EZ Ride.
- · Repairs not performed by a qualified technician.



BATTERY MUST NOT BE CLOSE TO EXTREME

HEAT OR COLD.

MAX 104°F

MIN -4°F

Patent Pending

WARNING


LI-ION 36V === 350 Wh 10.0 Ah Battery / Pile / Bateria 130501002DG9

To reduce the risk of injury, user must read Operator's Manual. Risk of fire and burns. Do not expose battery to Rain, Water, or Liquids, Open, Crush, Heat Above 104°F, Incinerate or Short Terminals. Follow Manufacturer's Instructions. Use only with charger listed in Operators Manual.

Remove Battery from unit when storing for long periods of time, changing attachments, or making adjustments.

> Shield Innovations LLC 107 Pinckney St. Oldsmar, FL 34677 888-987-4769

TOW BAR PARTS



CHAIR CLIP BREAKDOWN



Wheel chair clips



Chair clip cover

HITCH BREAKDOWN



TOW BAR INSTALLATION

Chair Clip



Place chair clip around horizontal or vertical wheel chair bar. Close to front of chair with screws facing outward.



Place chair clip cover over bar. Confirm it matches the curvature of the bar.



Screw small nut first until it meets the cover, do not tighten. Then place second lock nut on screw. **Do not tighten** completely.




Repeat on other side of chair. Make sure left and right clip are in the same position on the bar. Adjust clips to make as level as possible

TOW BAR INSTALLATION

Slide Tube



Make sure the chair is in the expanded position. The tow bar is spring loaded. Compress the slider tubes and line up with the chair clips.



Squeeze both the top and the bottom release buttons and push the slide tube into the chair clip until the release buttons pop through the chair clip hole. Do on both sides.




Move the tow bar hitch until it is centered between the two foot pads. Then tighten the 2 chair clips making sure the tow bar is level.



Tighten the 2 fastening knobs. It is normal for the tow bar to have some slight movement.

TOW BAR UN-INSTALL



Loosen both fastening knobs.



With one hand squeeze the chair clip release buttons and pull the slide tube toward the center until it releases from the chair clip.



Do the same on the other side. When both are released push both slide tubes to the center of the tow bar then remove from clips and tighten fastening knobs.

TOW BAR HITCH HEIGHT ADJUSTMENT



Normal position for EZ Ride tow bar hitch.



Raise tow bar hitch to lower front wheels of the chair closer to the ground.



Lower tow bar hitch to raise front wheels higher off the ground.




KICKSTAND INSTALLATION



To install kick stand insert kick stand over the plate with the two screws.



Make sure kick stand is straight along back side of EZ Ride.



Install two screw nuts and tighten with wrench.

Kickstand



HITCH HANDLE & KICKSTAND INSTALLATION





Position of the hitch handle assembly is NOT CORRECT.





CORRECT position for hitch handle, aligned even with white lines at top.



If adjustment needed, loosen Allen screws to move hitch handle assembly.



Once hitch handle is positioned, tighten using multi-tool.



Align kickstand screw inserts with white guide lines.




Tighten with multi-tool.


EZRIDE-WHEELCHAIR CONNECTION



While sitting in chair, using steering handle pull EZ ride towards tow bar hitch. Kickstand will automatically close.



Line up EZ Ride handle inside hitch receiver so handle is inserted **under** receiver rod.







Pull EZ ride towards you and once handle is under rod push up to engage tow bar hitch. Once locked in confirm front wheels are off the ground by at least 2-3". If not, adjust Towbar Hitch height. *see page 7*

EZRIDE-WHEELCHAIR RELEASE



To release EZ ride from Tow Bar push up on steering handle and at the same time lift EZ Ride handle up.



Holding on to EZ ride handle and steering bar Push down and forward to release EZ Ride from Tow Bar Hitch. Push EZ ride away from Chair to clear footrests.



Pull kickstand away from EZ Ride to the extended position. Insure it is flush to the ground. Make sure EZ Ride is on level ground when extending Kickstand.



record mileage

HANDLE FOLD INSTRUCTIONS



To fold handle to down position grab round release ring and pull towards handle grip.




Once release ring extended push handle to down position



To adjust angle of Brake or Speedometer turn Allen screw counter clockwise to loosen. Adjust to position desired and tighten Allen screw

HANDLE BAR REVERSAL INSTRUCTIONS

First, take off the front bracket by removing the four 4mm hex screws and rest the handle bars beside EZ-Ride.





Then loosen the two screws that clamp the handle bar stem to the steering column using a 5mm hex key. Only loosen the stem until it is able to rotate.



HANDLE BAR REVERSAL INSTRUCTIONS

Rotate the stem 180 degrees and looking down from the top of the EZ-Ride and line up the stem with the drive wheel. Once both are lined up properly, tighten the stem down switching between the two screws so they are both tightened down evenly.





Place the handle bars back on along with the bracket and start by hand tightening the four screws to get the threads started. Then tighten the screws in a pattern using the multitool so all screws will be tightened down evenly.



ADJUSTABLE NECK INSTALLATION

First, take off the front bracket by removing the four
(4) 4mm hex screws and rest the handle bars beside the EZRide.



2. Then loosen the two screws that clamp the handle bar stem to the steering column using a 5mm hex key, until the standard EZRide handle bar neck can be removed.

3. Place the new adjustable neck on the steering column as shown at right and tighten until it's securely in place.







ADJUSTABLE NECK INSTALLATION

4. Attach the handle bars to the adjustable neck by removing the four (4) hex screws and placing the handle bars as shown, and tighten until the handle bars are secure.

5. Adjust the neck angle by loosening the hex screw at the hinge, then tighten at the desired angle.





TOW BAR EXTENSION INSTALLATION

1. Use the included multitool and a wrench to loosen, and remove the 3 screws attaching the hitch to the tow bar.

2. Slide the hitch off the tow bar.

3. Slide the tow bar extension accessory onto the tow bar. Determine how far you want the EZRide to sit from the wheelchair - 3 or 6 inches.

4. Align the screw holes to the desired extension.



TOW BAR EXTENSION INSTALLATION

5. Insert the 3 screws. Fingertighten the nuts. Then, using the multi-tool and a wrench, tighten the screws to secure.


6. Slide the hitch on to the end of the tow bar extension, insert the centermost screw and finger-tighten.

7. Adjust the angle by tilting the hitch until the proper screw holes match. Then insert the remaining 2 screws. Tighten and secure all 3 screws.

8. This final installation image shows the tow bar extension set for 6 inch distance.











Insert three prong charging cable into port on top of EZ Ride.

Plug into normal 110 outlet.

Keep plugged in until light on charger turns green. Best to charge after each use.

Note: Like a car EZ Ride will lose charge over time if not used on a regular basis. Turn EZRide on periodically, check battery, and charge to full if display shows 2 bars or less.

BATTERY CHARGER TRAVEL BAG



Battery charger bag can be used for back of wheelchair mounting or clips can be joined together for hanging or shoulder use.








Read Instruction Manual Completely Before Using EZ Ride



DO NOT use medium or high speed indoors. Use eco speed only.




DO NOT make a 360 degree turn using medium or high speed.





DO NOT use EZ Ride on an incline of more than 30 degrees.





DO NOT use high speed until you are comfortable with eco & medium speed.



DO NOT use EZ Ride in sand or loose gravel.



More info at: www.buyezrideplus.com